

CORRIGENDUM

In the light of questioners received from prospective bidders regarding amendment/suggestions JREDA has decided to make following amendment in the NIB No. 30/JREDA/BEE/SLS(LED)/2013-14
NIB No. 30/JREDA/BEE/SLS(LED)/2013-14

1. Technical Specification

Sr. No.	Specifications	Required Value	Read as / Amended Value
1	Total Array LED Wattage (Rated Wattage)	90W (+3W)	90W ± 5%
4	Operating Temperature Range	-20 °C to +50 °C	-5 ⁰ ± 50 ⁰ C
13	Color Temperature	> 6000 °K	5500 – 6500 °K
15	Uniformity Ratio	> 0.4	As per BIS
17	Total Lumen Output	≥ 9200 lumens	≥ 8000 lumens
21	Luminary Housing	<ul style="list-style-type: none">• Pressure Die Cast Aluminum housing with corrosion resistant polyester powder coating & safety as per IEC60598 / IS 10322• Suitable for side entry mounting for 50mm to 60mm OD pipe bracket complete with bracket & locking bolt• Good thermal management system should be provided with suitable large surface area with fins to dissipate the heat to ambient air and block any accumulation of dust / water• Luminaries should be made up of 3/4 light modules with 3/ 4 individual drivers for each module (one driver should operate one module)	Luminaries should be made up of 2/3/4
22	Operating Voltage	110 V to 270V AC	140 V to 220 V

2. Queries

Sr. No.	Original Criteria	Amended / Read as
1	Clause No. 2.1 (d) The Bidder shall submit the test report of the quoted products, confirming to the applicable BIS / International Standard & DNIT specifications, with the bid, issued by Central / State Government (s) approved test laboratory / centre issued on or after 1st April, 2012. Those manufacturers who have the in-house testing facility i.e. laboratory, approved by the competent Govt. authority, may submit test report of the laboratory along with the copy of the letter approved by the Govt. Authority	In addition to the clause 2.1 (d) test certificate should be attached issued from approved NABL accredited test laboratories.
2.	Clause No. 2 (15) LED lamp, fitting Driver, Chip will be same manufacturer	Deleted.
3.	Page No. 8 Clause No. 4. The Participant should have valid CST/VAT/PAN/TAN No of Jharkhand State	Participants should submit current available valid VAT/CST, However they can submit Jharkhand VAT after award of the work.

1. The Corrigendum shall form the integral part of the tender documents.
2. The Amended complete NIB for each tender has been uploaded on JREDA website. The bidders shall download it & shall submit it duly signed with bid document.

Sd/-
Director