

## CORRIGENDUM

In the light of pre-bid meeting held on 31.10.2017 at 1.00 P.M. & suggestions received from the prospective bidders, JREDA has decided to make following amendments in the NIB No. **11/JREDA/SPV/SPP/17-18** for Design, Manufacture, Testing, Supply, Installation & Commissioning and Operation of 30 kWp SPV Power Plant and 150 Nos. of LED Street Lights (50W) including five years Comprehensive Maintenance Contract on Turnkey basis at Chandankiyari Chowk, Bokaro, Jharkhand:

Section/ Annexure	Original Criteria	Read as/ Amendments/Addendums												
<b>e- procurement Notice</b>	<p>Last date &amp; time for receipt of online bids: <b>13.11.2017 (Monday)</b> up to 05:00 PM</p> <p>Submission of original copies of Bid fee &amp; EMD (Offline) : <b>13.11.2017</b> and <b>14.11.2017</b> up to 5.00 P.M.</p> <p>Date &amp; Time for Technical Bid Opening : <b>16.11.2017 (Thursday)</b> at 03:00 PM</p>	<p>Last date &amp; time for receipt of online bids: <b>20.11.2017 (Monday)</b> up to 05:00 PM</p> <p>Submission of original copies of Bid fee &amp; EMD (Offline) : <b>20.11.2017</b> and <b>21.11.2017</b> up to 5.00 P.M.</p> <p>Date &amp; Time for Technical Bid Opening : <b>22.11.2017 (Wednesday)</b> at 03:00 PM</p>												
<b>Section-6</b>	<p><b>Page no. 24 of the NIB, Clause no. 1 of Technical Specification :</b></p> <table border="1" style="width: 100%;"> <thead> <tr> <th style="text-align: center;">Sr. No.</th> <th style="text-align: center;">Description</th> <th style="text-align: center;">Specification</th> </tr> </thead> <tbody> <tr> <td style="text-align: center;">2</td> <td style="text-align: center;">Battery Bank</td> <td style="text-align: center;">240V, 1200 AH Lead Acid Type, AGM-VRLA or Tubular Gel</td> </tr> </tbody> </table>	Sr. No.	Description	Specification	2	Battery Bank	240V, 1200 AH Lead Acid Type, AGM-VRLA or Tubular Gel	<p><b>Page no. 24 of the NIB, Clause no. 1 of Technical Specification:</b></p> <table border="1" style="width: 100%;"> <thead> <tr> <th style="text-align: center;">Sr. No.</th> <th style="text-align: center;">Description</th> <th style="text-align: center;">Specification</th> </tr> </thead> <tbody> <tr> <td style="text-align: center;">2</td> <td style="text-align: center;">Battery Bank</td> <td style="text-align: center;">120V, 1200 AH Lead Acid Type, AGM-VRLA or Tubular Gel</td> </tr> </tbody> </table>	Sr. No.	Description	Specification	2	Battery Bank	120V, 1200 AH Lead Acid Type, AGM-VRLA or Tubular Gel
Sr. No.	Description	Specification												
2	Battery Bank	240V, 1200 AH Lead Acid Type, AGM-VRLA or Tubular Gel												
Sr. No.	Description	Specification												
2	Battery Bank	120V, 1200 AH Lead Acid Type, AGM-VRLA or Tubular Gel												
<b>Section-6</b>	<p><b>Page no. 24 of the NIB, Clause no. 1 of Technical Specification :</b></p> <table border="1" style="width: 100%;"> <thead> <tr> <th style="text-align: center;">Sr. No.</th> <th style="text-align: center;">Description</th> <th style="text-align: center;">Specification</th> </tr> </thead> <tbody> <tr> <td style="text-align: center;">4</td> <td style="text-align: center;">Street Light Luminaries with Poles and Hardware</td> <td style="text-align: center;">150 Nos. LED Luminaries (50W) mounted on 150 Nos. of poles</td> </tr> </tbody> </table>	Sr. No.	Description	Specification	4	Street Light Luminaries with Poles and Hardware	150 Nos. LED Luminaries (50W) mounted on 150 Nos. of poles	<p><b>Page no. 24 of the NIB, Clause no. 1 of Technical Specification:</b></p> <table border="1" style="width: 100%;"> <thead> <tr> <th style="text-align: center;">Sr. No.</th> <th style="text-align: center;">Description</th> <th style="text-align: center;">Specification</th> </tr> </thead> <tbody> <tr> <td style="text-align: center;">4</td> <td style="text-align: center;">Street Light Luminaries with Poles and Hardware</td> <td style="text-align: center;">150 Nos. LED Luminaries (50W) mounted on 150 Nos. of Octagonal GI poles Poles Specification: Top dia. (A/F): 70 mm Bottom dia. (A/F):130mm Sheet Thickness: 3mm Base Plate (LxBxT): 220x220x12 Anchor Plate Thickness: 3mm The poles should be fixed on RCC Structure.</td> </tr> </tbody> </table>	Sr. No.	Description	Specification	4	Street Light Luminaries with Poles and Hardware	150 Nos. LED Luminaries (50W) mounted on 150 Nos. of Octagonal GI poles Poles Specification: Top dia. (A/F): 70 mm Bottom dia. (A/F):130mm Sheet Thickness: 3mm Base Plate (LxBxT): 220x220x12 Anchor Plate Thickness: 3mm The poles should be fixed on RCC Structure.
Sr. No.	Description	Specification												
4	Street Light Luminaries with Poles and Hardware	150 Nos. LED Luminaries (50W) mounted on 150 Nos. of poles												
Sr. No.	Description	Specification												
4	Street Light Luminaries with Poles and Hardware	150 Nos. LED Luminaries (50W) mounted on 150 Nos. of Octagonal GI poles Poles Specification: Top dia. (A/F): 70 mm Bottom dia. (A/F):130mm Sheet Thickness: 3mm Base Plate (LxBxT): 220x220x12 Anchor Plate Thickness: 3mm The poles should be fixed on RCC Structure.												

<b>Section-6</b>	<b>Page no. 25 of the NIB, Clause no. 1 of Technical Specification:</b>  <table border="1" data-bbox="306 204 1148 272"> <thead> <tr> <th data-bbox="306 204 447 240">Sr. No.</th> <th data-bbox="447 204 726 240">Description</th> <th data-bbox="726 204 1148 240">Specification</th> </tr> </thead> <tbody> <tr> <td data-bbox="306 240 447 272">5</td> <td data-bbox="447 240 726 272">Control Room</td> <td data-bbox="726 240 1148 272">About 100 sq. ft.</td> </tr> </tbody> </table>	Sr. No.	Description	Specification	5	Control Room	About 100 sq. ft.	<b>Page no. 25 of the NIB, Clause no. 1 of Technical Specification:</b>  <table border="1" data-bbox="1173 204 2016 370"> <thead> <tr> <th data-bbox="1173 204 1314 240">Sr. No.</th> <th data-bbox="1314 204 1598 240">Description</th> <th data-bbox="1598 204 2016 240">Specification</th> </tr> </thead> <tbody> <tr> <td data-bbox="1173 240 1314 370">5</td> <td data-bbox="1314 240 1598 370">Control Room</td> <td data-bbox="1598 240 2016 370">Approx. 4.0m x 4.0m= 16m<sup>2</sup> and Height- 12 feet. (Masonry- RCC roof structure)</td> </tr> </tbody> </table>	Sr. No.	Description	Specification	5	Control Room	Approx. 4.0m x 4.0m= 16m <sup>2</sup> and Height- 12 feet. (Masonry- RCC roof structure)
Sr. No.	Description	Specification												
5	Control Room	About 100 sq. ft.												
Sr. No.	Description	Specification												
5	Control Room	Approx. 4.0m x 4.0m= 16m <sup>2</sup> and Height- 12 feet. (Masonry- RCC roof structure)												
<b>Section-6</b>	<b>Page no. 25 of the NIB, Clause no. 1 of Technical Specification:</b>  <b>Battery Bank</b> A 240V, 2500 AH (at C/10 rate) Battery Bank should be used in the system for storing the generated energy. The battery bank in the offered SPV systems should be maintenance free type for SPV application Lead Acid type AGM-VRLA or tubular Gel.	<b>Page no. 25 of the NIB, Clause no. 1 of Technical Specification:</b>  <b>Battery Bank</b> A 240V, 1200 AH, 2V (at C/10 rate) Battery Bank should be used in the system for storing the generated energy. The battery bank in the offered SPV systems should be maintenance free type for SPV application Lead Acid type AGM-VRLA or tubular Gel.												

2. Changes made as above in NIB may be read accordingly for similar changes in related technical specification.
3. The Corrigendum shall form the integral part of the tender documents.

Sd/-  
Director  
JREDA, Ranchi

