

## **CORRIGENDUM II**

NIB No. **11/JREDA/SPV/SPP/17-18** for Design, Manufacture, Testing, Supply, Installation & Commissioning and Operation of 30 kWp SPV Power Plant and 150 Nos. of LED Street Lights (50W) including five years Comprehensive Maintenance Contract on Turnkey basis at Chandankiyari Chowk, Bokaro, Jharkhand:

<b>Section/ Annexure</b>	<b>Original Criteria</b>	<b>Read as/ Amendments/Addendums</b>												
<b>Section-6</b>	<b>Page no. 24 of the NIB, Clause no. 1 of Technical Specification :</b> <table border="1"><thead><tr><th><b>Sr. No.</b></th><th><b>Description</b></th><th><b>Specification</b></th></tr></thead><tbody><tr><td>2</td><td>Battery Bank</td><td>120V, 1200 AH Lead Acid Type, AGM-VRLA or Tubular Gel</td></tr></tbody></table>	<b>Sr. No.</b>	<b>Description</b>	<b>Specification</b>	2	Battery Bank	120V, 1200 AH Lead Acid Type, AGM-VRLA or Tubular Gel	<b>Page no. 24 of the NIB, Clause no. 1 of Technical Specification:</b> <table border="1"><thead><tr><th><b>Sr. No.</b></th><th><b>Description</b></th><th><b>Specification</b></th></tr></thead><tbody><tr><td>2</td><td>Battery Bank</td><td>240V, 1200 AH Lead Acid Type, AGM-VRLA or Tubular Gel</td></tr></tbody></table>	<b>Sr. No.</b>	<b>Description</b>	<b>Specification</b>	2	Battery Bank	240V, 1200 AH Lead Acid Type, AGM-VRLA or Tubular Gel
<b>Sr. No.</b>	<b>Description</b>	<b>Specification</b>												
2	Battery Bank	120V, 1200 AH Lead Acid Type, AGM-VRLA or Tubular Gel												
<b>Sr. No.</b>	<b>Description</b>	<b>Specification</b>												
2	Battery Bank	240V, 1200 AH Lead Acid Type, AGM-VRLA or Tubular Gel												
<b>Section-6</b>	<b>Page no. 26 of the NIB, Clause no. 1 of Technical Specification :</b> <b>Power Conditioning Unit</b> <table border="1"><thead><tr><th><b>Operating Parameters</b></th><th><b>Specification</b></th></tr></thead><tbody><tr><td>Continuous Rating</td><td>300 KVA</td></tr></tbody></table>	<b>Operating Parameters</b>	<b>Specification</b>	Continuous Rating	300 KVA	<b>Page no. 26 of the NIB, Clause no. 1 of Technical Specification :</b> <b>Power Conditioning Unit</b> <table border="1"><thead><tr><th><b>Operating Parameters</b></th><th><b>Specification</b></th></tr></thead><tbody><tr><td>Continuous Rating</td><td>30 KVA</td></tr></tbody></table>	<b>Operating Parameters</b>	<b>Specification</b>	Continuous Rating	30 KVA				
<b>Operating Parameters</b>	<b>Specification</b>													
Continuous Rating	300 KVA													
<b>Operating Parameters</b>	<b>Specification</b>													
Continuous Rating	30 KVA													

2. Changes made as above in NIB may be read accordingly for similar changes in related technical specification.
3. The Corrigendum shall form the integral part of the tender documents.

Sd/-  
Director  
JREDA, Ranchi

