

**JHARKHAND RENEWABLE ENERGY DEVELOPMENT AGENCY**  
328/B, Road No.4, Ashoknagar, Ranchi.

**NIB No. JREDA/SPV/SPP/Police Pickets/01/2011-12 dated: 05.05.11**

**NOTICE**  
**Clarification/Corrections/Amendments**

- Electronics/Inverters or Power Conditioning Unit of SPV Power Plant (2.5 & 5.0 KW) in the NIB should preferably be IEC certified. However bidder should enclose an undertaking that the PCU supplied confirms the performance as per MNRE specifications/requirements.

Date:27.05.2011

DIRECTOR  
JREDA